

FOH0338

US EPA RECORDS CENTER REGION 5



464477

To: Troy  
Industrial Wastes

Southwest District Office  
Knott Bldg. - 3rd Floor  
40 South Main Street  
Dayton, Ohio 45402  
Tel. 461-5490

September 29, 1970

Mr. Edward A. Hobart  
Hobart Brothers  
600 W. Main Street  
Troy, Ohio 45373

Dear Mr. Hobart:

This letter confirms the results of the conference held at the Southwest District Office on September 14, 1970 with you and Mr. Don Kuras of your staff and Mr. W. E. Spies, Principal District Sanitary Engineer and myself.

This office concurs in your proposed general plan for the treatment of industrial wastes being discharged from your manufacturing complex at the intersection of Ridge Road and Trade Road East. It is our understanding that this includes the installation of a closed-loop system for your cooling waters, the installation of collection and batch treatment facilities for other industrial wastes, and the installation of a settling pit for removal of settleable solids from boiler blow down water. Since the volume of treated industrial wastes is expected to be on the order of 6,000 gal/day, this office would have no objection to its discharge into the sanitary sewer providing permission is obtained from the City of Troy. Final approval of your industrial waste treatment system can be considered only after receipt and evaluation of your detail plans for these projects.

You will still be required to obtain a permit from the Water Pollution Control Board for the discharge of your industrial wastes into "waters of the state". Your application for this permit should be submitted immediately. However, after approval and construction of your proposed facilities this permit will no longer be necessary if there are no discharges into "waters of the state".

Should you have any questions with respect to the above, please feel free to call on us at any time.

Very truly yours,

Charles W. Forsthoff  
District Sanitary Engineer

CWF:mas

cc: Kurt C. Becker, M.D.  
Health Commissioner  
cc: Water Pollution Control Board  
cc: Mr. Marlon Heber, Director  
Public Service & Safety